

부록6. 서식II-01-06, 온도기록지(IP 보관)

IP STORAGE TEMPERATURE LOG

Storage Subject	Description	약품냉장고	Storage Space	냉장고
	Manufacturer	Giant Star	Storage Period	2022.11
	Model Name	CBR1000SS	Investigational Product	냉장보관대상 IP
	Serial Number	GS17090102-10		
Calibration Subject	Probe Position	Left		
	Description	Digital Thermometer		
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	825287		
	Date of Calibration	2022.4.4		
	Certificate No.	22008908-4		
	Probe Position	Right		
	Description	Digital Thermometer		
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	2102992		
	Date of Calibration	2022.4.4		
	Certificate No.	22008908-8	Temperature Range	2~8℃

Date	Time	Probe Position	Temperature(℃)			Verified by	Comment
			Min	Max	Current		
2022.11.01	13:00	Left	4	7	6	[Signature]	
		Right	3	4	3		
2022.11.02	13:30	Left	4	7	6	[Signature]	
		Right	3	4	4		
2022.11.03	13:30	Left	4	7	6	[Signature]	
		Right	3	4	4		
2022.11.04	13:30	Left	3	7	6	[Signature]	
		Right	2	4	3		
2022.11.05		Left					
		Right					
2022.11.06		Left					
		Right					
2022.11.07	13:30	Left	4	7	6	[Signature]	
		Right	3	4	4		
2022.11.08	13:30	Left	4	7	6	[Signature]	
		Right	3	4	4		
2022.11.09	13:30	Left	4	7	6	[Signature]	
		Right	3	4	3		
2022.11.10	13:30	Left	4	7	6	[Signature]	
		Right	3	4	4		
2022.11.11	13:30	Left	3	7	5	[Signature]	
		Right	2	4	3		
2022.11.12		Left					
		Right					

부록6. 서식II-01-06, 온도기록지(IP 보관)

IP STORAGE TEMPERATURE LOG

Storage Subject	Description	약품냉장고	Storage Space	냉장고
	Manufacturer	Giant Star	Storage Period	2022.11
	Model Name	CBR1000SS	Investigational Product	냉장보관대상 IP
	Serial Number	GS17090102-10		
Calibration Subject	Probe Position	Left		
	Description	Digital Thermometer		
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	825287		
	Date of Calibration	2022.4.4		
	Certificate No.	22008908-4		
	Probe Position	Right		
	Description	Digital Thermometer		
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	2102992		
	Date of Calibration	2022.4.4		
	Certificate No.	22008908-8		
			Temperature Range	2~8°C

Date	Time	Probe Position	Temperature(°C)			Verified by	Comment
			Min	Max	Current		
2022.11.13		Left					
		Right					
2022.11.14	1:30	Left	3	7	4	aul	
		Right	2	5	4		
2022.11.15	1:30	Left	4	7	6	aul	
		Right	3	4	4		
2022.11.16	1:30	Left	2	7	5	aul	
		Right	2	4	3		
2022.11.17	1:30	Left	2	6	5	aul	
		Right	3	4	4		
2022.11.18	1:30	Left	2	6	6	aul	
		Right	3	4	4		
2022.11.19		Left					
		Right					
2022.11.20		Left					
		Right					
2022.11.21	1:30	Left	2	6	5	aul	
		Right	2	4	4		
2022.11.22	1:30	Left	2	6	6	aul	
		Right	3	4	4		
2022.11.23	1:30	Left	3	7	5	aul	LB001 IP 0602
		Right	3	4	4		
2022.11.24	1:30	Left	2	6	5	aul	
		Right	3	5	4		

부록6. 서식II-01-06, 온도기록지(IP 보관)

IP STORAGE TEMPERATURE LOG

Storage Subject	Description	약품냉장고	Storage Space	냉장고
	Manufacturer	Giant Star	Storage Period	2022.11
	Model Name	CBR1000SS	Investigational Product	냉장보관대상 IP
	Serial Number	GS17090102-10		
Calibration Subject	Probe Position	Left		
	Description	Digital Thermometer		
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	825287		
	Date of Calibration	2022.4.4		
	Certificate No.	22008908-4		
	Probe Position	Right		
	Description	Digital Thermometer		
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	2102992		
	Date of Calibration	2022.4.4		
	Certificate No.	22008908-8	Temperature Range	2~8℃

Date	Time	Probe Position	Temperature(℃)			Verified by	Comment
			Min	Max	Current		
2022.11.25	p:30	Left	3	6	4	ml	
		Right	3	4	4		
2022.11.26		Left					
		Right					
2022.11.27		Left					
		Right					
2022.11.28	p:30	Left	3	6	4	ml	
		Right	3	4	4		
2022.11.29	p:30	Left	3	7	5	ml	
		Right	3	4	4		
2022.11.30	p:30	Left	2	6	6	ml	
		Right	3	4	4		
1900-01-00		Left					
		Right					

date of copying

sign

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.5 DV: 0.5
 21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.5 DV: 0.5
 19:18 SP: 4.0 PV: 4.0 DV: 0.0
 18:18 SP: 4.0 PV: 3.8 DV: -0.2
 17:18 SP: 4.0 PV: 4.3 DV: 0.3
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.5 DV: 0.5
 14:18 SP: 4.0 PV: 3.8 DV: -0.2
 13:18 SP: 4.0 PV: 4.2 DV: 0.2
 12:18 SP: 4.0 PV: 3.7 DV: -0.3
 11:18 SP: 4.0 PV: 4.4 DV: 0.4
 10:18 SP: 4.0 PV: 4.1 DV: 0.1
 09:18 SP: 4.0 PV: 4.2 DV: 0.2
 08:18 SP: 4.0 PV: 3.7 DV: -0.3
 07:18 SP: 4.0 PV: 4.4 DV: 0.4
 06:18 SP: 4.0 PV: 4.1 DV: 0.1
 05:18 SP: 4.0 PV: 3.8 DV: -0.2
 04:18 SP: 4.0 PV: 4.3 DV: 0.3
 03:18 SP: 4.0 PV: 3.7 DV: -0.3
 02:18 SP: 4.0 PV: 4.4 DV: 0.4
 01:18 SP: 4.0 PV: 3.7 DV: -0.3
 00:18 SP: 4.0 PV: 4.4 DV: 0.4

2022-11-02

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.4 DV: 0.4
 21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.4 DV: 0.4
 19:18 SP: 4.0 PV: 3.7 DV: -0.3
 18:18 SP: 4.0 PV: 4.3 DV: 0.3
 17:18 SP: 4.0 PV: 3.7 DV: -0.3
 16:18 SP: 4.0 PV: 4.4 DV: 0.4
 15:18 SP: 4.0 PV: 3.7 DV: -0.3
 14:18 SP: 4.0 PV: 4.3 DV: 0.3
 13:18 SP: 4.0 PV: 4.2 DV: 0.2
 12:18 SP: 4.0 PV: 3.9 DV: -0.1
 11:18 SP: 4.0 PV: 4.3 DV: 0.3

2

10:18 SP: 4.0 PV: 4.2 DV: 0.
 09:18 SP: 4.0 PV: 3.8 DV: -0.2
 08:18 SP: 4.0 PV: 4.4 DV: 0.4
 07:18 SP: 4.0 PV: 3.7 DV: -0.3
 06:18 SP: 4.0 PV: 4.4 DV: 0.4
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.4 DV: 0.4

3

03:18 SP: 4.0 PV: 3.7 DV: -0.

4

02:18 SP: 4.0 PV: 4.4 DV: 0.
 01:18 SP: 4.0 PV: 3.7 DV: -0.3
 00:18 SP: 4.0 PV: 4.5 DV: 0.5
 2022-11-01

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.4 DV: 0.4
 21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.5 DV: 0.5
 19:18 SP: 4.0 PV: 3.9 DV: -0.1
 18:18 SP: 4.0 PV: 4.6 DV: 0.6
 17:18 SP: 4.0 PV: 3.9 DV: -0.1
 16:18 SP: 4.0 PV: 4.5 DV: 0.5
 15:18 SP: 4.0 PV: 3.8 DV: -0.2
 14:18 SP: 4.0 PV: 4.6 DV: 0.6
 13:18 SP: 4.0 PV: 3.9 DV: -0.1
 12:18 SP: 4.0 PV: 4.6 DV: 0.6
 11:18 SP: 4.0 PV: 3.9 DV: -0.1
 10:18 SP: 4.0 PV: 4.3 DV: 0.3
 09:18 SP: 4.0 PV: 3.7 DV: -0.3
 08:18 SP: 4.0 PV: 4.6 DV: 0.6
 07:18 SP: 4.0 PV: 3.9 DV: -0.1
 06:18 SP: 4.0 PV: 4.4 DV: 0.4
 05:18 SP: 4.0 PV: 4.6 DV: 0.6
 04:18 SP: 4.0 PV: 4.0 DV: 0.0
 03:18 SP: 4.0 PV: 4.5 DV: 0.5
 02:18 SP: 4.0 PV: 4.7 DV: 0.7
 01:18 SP: 4.0 PV: 4.4 DV: 0.4
 00:18 SP: 4.0 PV: 4.3 DV: 0.3

2022-11-04

23:18 SP: 4.0 PV: 3.9 DV: -0.1
 22:18 SP: 4.0 PV: 4.4 DV: 0.4
 21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.5 DV: 0.5
 19:18 SP: 4.0 PV: 3.8 DV: -0.2
 18:18 SP: 4.0 PV: 4.2 DV: 0.2
 17:18 SP: 4.0 PV: 3.7 DV: -0.3
 16:18 SP: 4.0 PV: 4.4 DV: 0.4
 15:18 SP: 4.0 PV: 3.8 DV: -0.2
 14:18 SP: 4.0 PV: 4.3 DV: 0.3
 13:18 SP: 4.0 PV: 3.7 DV: -0.3
 12:18 SP: 4.0 PV: 4.5 DV: 0.5
 11:18 SP: 4.0 PV: 3.9 DV: -0.1
 10:18 SP: 4.0 PV: 4.2 DV: 0.2
 09:18 SP: 4.0 PV: 4.1 DV: 0.1
 08:18 SP: 4.0 PV: 4.2 DV: 0.2
 07:18 SP: 4.0 PV: 4.0 DV: 0.0
 06:18 SP: 4.0 PV: 4.2 DV: 0.2
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.4 DV: 0.4
 03:18 SP: 4.0 PV: 3.7 DV: -0.3
 02:18 SP: 4.0 PV: 4.4 DV: 0.4
 01:18 SP: 4.0 PV: 3.7 DV: -0.3
 00:18 SP: 4.0 PV: 4.5 DV: 0.5

2022-11-03

SP Setting Point
 PV Present Value
 DV Difference Value

23:18 SP: 4.0 PV: 4.6 DV: 0.6
22:18 SP: 4.0 PV: 3.9 DV: -0.1
21:18 SP: 4.0 PV: 4.6 DV: 0.6
20:18 SP: 4.0 PV: 3.9 DV: -0.1
19:18 SP: 4.0 PV: 4.5 DV: 0.5
18:18 SP: 4.0 PV: 3.9 DV: -0.1
17:18 SP: 4.0 PV: 4.5 DV: 0.5
16:18 SP: 4.0 PV: 3.7 DV: -0.3
15:18 SP: 4.0 PV: 4.4 DV: 0.4
14:18 SP: 4.0 PV: 3.7 DV: -0.3
13:18 SP: 4.0 PV: 4.4 DV: 0.4
12:18 SP: 4.0 PV: 4.0 DV: 0.0
11:18 SP: 4.0 PV: 4.6 DV: 0.6
10:18 SP: 4.0 PV: 3.9 DV: -0.1
09:18 SP: 4.0 PV: 4.6 DV: 0.6
08:18 SP: 4.0 PV: 3.8 DV: -0.2
07:18 SP: 4.0 PV: 4.5 DV: 0.5
06:18 SP: 4.0 PV: 3.7 DV: -0.3
05:18 SP: 4.0 PV: 4.3 DV: 0.3
04:18 SP: 4.0 PV: 4.2 DV: 0.2
03:18 SP: 4.0 PV: 3.8 DV: -0.2
02:18 SP: 4.0 PV: 4.3 DV: 0.3
01:18 SP: 4.0 PV: 3.7 DV: -0.3
00:18 SP: 4.0 PV: 4.4 DV: 0.4
2022-11-06
23:18 SP: 4.0 PV: 3.7 DV: -0.3
22:18 SP: 4.0 PV: 4.3 DV: 0.3
21:18 SP: 4.0 PV: 3.7 DV: -0.3
20:18 SP: 4.0 PV: 4.4 DV: 0.4
19:18 SP: 4.0 PV: 4.0 DV: 0.0
18:18 SP: 4.0 PV: 4.6 DV: 0.6
17:18 SP: 4.0 PV: 3.8 DV: -0.2
16:18 SP: 4.0 PV: 4.5 DV: 0.5
15:18 SP: 4.0 PV: 3.7 DV: -0.3
14:18 SP: 4.0 PV: 4.5 DV: 0.5
13:18 SP: 4.0 PV: 3.9 DV: -0.1
12:18 SP: 4.0 PV: 4.2 DV: 0.2
11:18 SP: 4.0 PV: 3.7 DV: -0.3
10:18 SP: 4.0 PV: 4.4 DV: 0.4
09:18 SP: 4.0 PV: 4.0 DV: 0.0
08:18 SP: 4.0 PV: 4.2 DV: 0.2
07:18 SP: 4.0 PV: 3.8 DV: -0.2
06:18 SP: 4.0 PV: 4.3 DV: 0.3
05:18 SP: 4.0 PV: 4.1 DV: 0.1
04:18 SP: 4.0 PV: 3.8 DV: -0.2
03:18 SP: 4.0 PV: 4.3 DV: 0.3
02:18 SP: 4.0 PV: 4.1 DV: 0.1
01:18 SP: 4.0 PV: 3.8 DV: -0.2
00:18 SP: 4.0 PV: 4.3 DV: 0.3
2022-11-05

1
23:18 SP: 4.0 PV: 3.9 DV: -0.1
22:18 SP: 4.0 PV: 4.3 DV: 0.3
21:18 SP: 4.0 PV: 3.8 DV: -0.2
20:18 SP: 4.0 PV: 4.3 DV: 0.3
19:18 SP: 4.0 PV: 3.7 DV: -0.3
18:18 SP: 4.0 PV: 4.3 DV: 0.3
17:18 SP: 4.0 PV: 3.7 DV: -0.3
16:18 SP: 4.0 PV: 4.4 DV: 0.4
15:18 SP: 4.0 PV: 4.0 DV: 0.0
14:18 SP: 4.0 PV: 4.6 DV: 0.6
13:18 SP: 4.0 PV: 3.9 DV: -0.1
12:18 SP: 4.0 PV: 4.5 DV: 0.5
11:18 SP: 4.0 PV: 3.9 DV: -0.1
10:18 SP: 4.0 PV: 4.5 DV: 0.5
09:18 SP: 4.0 PV: 3.9 DV: -0.1
08:18 SP: 4.0 PV: 4.6 DV: 0.6
07:18 SP: 4.0 PV: 3.7 DV: -0.3
06:18 SP: 4.0 PV: 4.3 DV: 0.3
05:18 SP: 4.0 PV: 4.2 DV: 0.2
04:18 SP: 4.0 PV: 4.3 DV: 0.3
03:18 SP: 4.0 PV: 4.6 DV: 0.6
02:18 SP: 4.0 PV: 4.1 DV: 0.1
01:18 SP: 4.0 PV: 4.5 DV: 0.5
00:18 SP: 4.0 PV: 4.0 DV: 0.0
2022-11-08
23:18 SP: 4.0 PV: 4.6 DV: 0.6
22:18 SP: 4.0 PV: 4.0 DV: 0.0
21:18 SP: 4.0 PV: 4.6 DV: 0.6
20:18 SP: 4.0 PV: 4.0 DV: 0.0
19:18 SP: 4.0 PV: 4.3 DV: 0.3
18:18 SP: 4.0 PV: 4.6 DV: 0.6
17:18 SP: 4.0 PV: 3.8 DV: -0.2
16:18 SP: 4.0 PV: 4.5 DV: 0.5
15:18 SP: 4.0 PV: 4.0 DV: 0.0
6
14:18 SP: 4.0 PV: 4.6 DV: 0.6
13:18 SP: 4.0 PV: 3.7 DV: -0.3
12:18 SP: 4.0 PV: 4.4 DV: 0.4
11:18 SP: 4.0 PV: 3.7 DV: -0.3
10:18 SP: 4.0 PV: 4.4 DV: 0.4
09:18 SP: 4.0 PV: 4.7 DV: 0.7
08:18 SP: 4.0 PV: 3.9 DV: -0.1
07:18 SP: 4.0 PV: 4.6 DV: 0.6
06:18 SP: 4.0 PV: 3.8 DV: -0.2
05:18 SP: 4.0 PV: 4.5 DV: 0.5
04:18 SP: 4.0 PV: 3.8 DV: -0.2
03:18 SP: 4.0 PV: 4.5 DV: 0.5
02:18 SP: 4.0 PV: 3.8 DV: -0.2
01:18 SP: 4.0 PV: 4.5 DV: 0.5
00:18 SP: 4.0 PV: 3.9 DV: -0.1
2022-11-07

SP Setting Point
PV Present Value
DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 3.8 DV: -0.2
 22:18 SP: 4.0 PV: 4.3 DV: 0.3
 21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.4 DV: 0.4
 19:18 SP: 4.0 PV: 3.7 DV: -0.3
 18:18 SP: 4.0 PV: 4.4 DV: 0.4
 17:18 SP: 4.0 PV: 3.7 DV: -0.3
 16:18 SP: 4.0 PV: 4.5 DV: 0.5
 15:18 SP: 4.0 PV: 3.7 DV: -0.3
 14:18 SP: 4.0 PV: 4.5 DV: 0.5
 13:18 SP: 4.0 PV: 3.7 DV: -0.3
 12:18 SP: 4.0 PV: 4.5 DV: 0.5
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.4 DV: 0.4
 09:18 SP: 4.0 PV: 4.6 DV: 0.6
 08:18 SP: 4.0 PV: 3.8 DV: -0.2
 07:18 SP: 4.0 PV: 4.5 DV: 0.5
 06:18 SP: 4.0 PV: 4.0 DV: 0.0
 05:18 SP: 4.0 PV: 4.6 DV: 0.6
 04:18 SP: 4.0 PV: 3.7 DV: -0.3
 03:18 SP: 4.0 PV: 4.4 DV: 0.4
 02:18 SP: 4.0 PV: 4.0 DV: 0.0
 01:18 SP: 4.0 PV: 4.6 DV: 0.6
 00:18 SP: 4.0 PV: 3.8 DV: -0.2

2022-11-10

23:18 SP: 4.0 PV: 4.4 DV: 0.4
 22:18 SP: 4.0 PV: 4.0 DV: 0.0
 21:18 SP: 4.0 PV: 4.6 DV: 0.6
 20:18 SP: 4.0 PV: 3.9 DV: -0.1
 19:18 SP: 4.0 PV: 4.5 DV: 0.5
 18:18 SP: 4.0 PV: 3.9 DV: -0.1
 17:18 SP: 4.0 PV: 4.5 DV: 0.5
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.6 DV: 0.6
 14:18 SP: 4.0 PV: 3.7 DV: -0.3
 13:18 SP: 4.0 PV: 4.3 DV: 0.3
 12:18 SP: 4.0 PV: 4.5 DV: 0.5
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.4 DV: 0.4
 09:18 SP: 4.0 PV: 3.7 DV: -0.3
 08:18 SP: 4.0 PV: 4.4 DV: 0.4
 07:18 SP: 4.0 PV: 3.7 DV: -0.3
 06:18 SP: 4.0 PV: 4.4 DV: 0.4
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.5 DV: 0.5
 03:18 SP: 4.0 PV: 3.7 DV: -0.3
 02:18 SP: 4.0 PV: 4.5 DV: 0.5
 01:18 SP: 4.0 PV: 4.0 DV: 0.0
 00:18 SP: 4.0 PV: 4.6 DV: 0.6

2022-11-09

23:18 SP: 4.0 PV: 4.2 DV: 0.2
 22:18 SP: 4.0 PV: 3.8 DV: -0.2
 21:18 SP: 4.0 PV: 4.3 DV: 0.3
 20:18 SP: 4.0 PV: 4.2 DV: 0.2
 19:18 SP: 4.0 PV: 4.2 DV: 0.2
 18:18 SP: 4.0 PV: 3.7 DV: -0.3
 17:18 SP: 4.0 PV: 4.3 DV: 0.3
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.4 DV: 0.4
 14:18 SP: 4.0 PV: 4.0 DV: 0.0
 13:18 SP: 4.0 PV: 3.8 DV: -0.2
 12:18 SP: 4.0 PV: 4.3 DV: 0.3
 11:18 SP: 4.0 PV: 4.0 DV: 0.0
 10:18 SP: 4.0 PV: 3.8 DV: -0.2
 09:18 SP: 4.0 PV: 4.3 DV: 0.3
 08:18 SP: 4.0 PV: 3.7 DV: -0.3
 07:18 SP: 4.0 PV: 4.3 DV: 0.3
 06:18 SP: 4.0 PV: 4.6 DV: 0.6
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.3 DV: 0.3
 03:18 SP: 4.0 PV: 4.6 DV: 0.6
 02:18 SP: 4.0 PV: 3.7 DV: -0.3
 01:18 SP: 4.0 PV: 4.3 DV: 0.3
 00:18 SP: 4.0 PV: 4.5 DV: 0.5

2022-11-12

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.5 DV: 0.5

3

21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.6 DV: 0.6
 19:18 SP: 4.0 PV: 3.8 DV: -0.2
 18:18 SP: 4.0 PV: 4.2 DV: 0.2
 17:18 SP: 4.0 PV: 3.7 DV: -0.3
 16:18 SP: 4.0 PV: 4.4 DV: 0.4
 15:18 SP: 4.0 PV: 3.7 DV: -0.3
 14:18 SP: 4.0 PV: 4.3 DV: 0.3
 13:18 SP: 4.0 PV: 3.7 DV: -0.3
 12:18 SP: 4.0 PV: 4.3 DV: 0.3
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.5 DV: 0.5
 09:18 SP: 4.0 PV: 3.8 DV: -0.2
 08:18 SP: 4.0 PV: 4.5 DV: 0.5
 07:18 SP: 4.0 PV: 3.8 DV: -0.2
 06:18 SP: 4.0 PV: 4.6 DV: 0.6
 05:18 SP: 4.0 PV: 3.9 DV: -0.1
 04:18 SP: 4.0 PV: 4.6 DV: 0.6
 03:18 SP: 4.0 PV: 3.8 DV: -0.2
 02:18 SP: 4.0 PV: 4.6 DV: 0.6
 01:18 SP: 4.0 PV: 3.8 DV: -0.2
 00:18 SP: 4.0 PV: 4.5 DV: 0.5

2022-11-11

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 3.8 DV: -0.2
 22:18 SP: 4.0 PV: 4.6 DV: 0.6
 21:18 SP: 4.0 PV: 3.8 DV: -0.2
 20:18 SP: 4.0 PV: 4.6 DV: 0.6
 19:18 SP: 4.0 PV: 3.8 DV: -0.2
 18:18 SP: 4.0 PV: 4.6 DV: 0.6
 17:18 SP: 4.0 PV: 3.9 DV: -0.1
 16:18 SP: 4.0 PV: 4.6 DV: 0.6
 15:18 SP: 4.0 PV: 3.7 DV: -0.3
 14:18 SP: 4.0 PV: 4.3 DV: 0.3
 13:18 SP: 4.0 PV: 3.7 DV: -0.3
 12:18 SP: 4.0 PV: 4.4 DV: 0.4
 11:18 SP: 4.0 PV: 4.2 DV: 0.2
 10:18 SP: 4.0 PV: 3.7 DV: -0.3
 09:18 SP: 4.0 PV: 4.3 DV: 0.3
 08:18 SP: 4.0 PV: 4.3 DV: 0.3
 07:18 SP: 4.0 PV: 3.7 DV: -0.3
 06:18 SP: 4.0 PV: 4.3 DV: 0.3
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.5 DV: 0.5
 03:18 SP: 4.0 PV: 3.9 DV: -0.1
 02:18 SP: 4.0 PV: 4.2 DV: 0.2

3

01:18 SP: 4.0 PV: 3.7 DV: -0.
 00:18 SP: 4.0 PV: 4.3 DV: 0.3

2022-11-14

23:18 SP: 4.0 PV: 4.2 DV: 0.2
 22:18 SP: 4.0 PV: 3.8 DV: -0.2
 21:18 SP: 4.0 PV: 4.3 DV: 0.3
 20:18 SP: 4.0 PV: 3.7 DV: -0.3
 19:18 SP: 4.0 PV: 4.4 DV: 0.4

3

18:18 SP: 4.0 PV: 3.7 DV: -0.
 17:18 SP: 4.0 PV: 4.6 DV: 0.6
 16:18 SP: 4.0 PV: 3.9 DV: -0.1
 15:18 SP: 4.0 PV: 4.2 DV: 0.2
 14:18 SP: 4.0 PV: 3.7 DV: -0.3
 13:18 SP: 4.0 PV: 4.4 DV: 0.4
 12:18 SP: 4.0 PV: 3.7 DV: -0.3
 11:18 SP: 4.0 PV: 4.6 DV: 0.6
 10:18 SP: 4.0 PV: 3.8 DV: -0.2
 09:18 SP: 4.0 PV: 4.3 DV: 0.3
 08:18 SP: 4.0 PV: 3.7 DV: -0.3
 07:18 SP: 4.0 PV: 4.3 DV: 0.3
 06:18 SP: 4.0 PV: 4.2 DV: 0.2
 05:18 SP: 4.0 PV: 4.2 DV: 0.2
 04:18 SP: 4.0 PV: 3.8 DV: -0.2
 03:18 SP: 4.0 PV: 4.4 DV: 0.4
 02:18 SP: 4.0 PV: 3.7 DV: -0.3
 01:18 SP: 4.0 PV: 4.4 DV: 0.4
 00:18 SP: 4.0 PV: 4.1 DV: 0.1

2022-11-13

23:18 SP: 4.0 PV: 4.1 DV: 0.1
 22:18 SP: 4.0 PV: 4.2 DV: 0.2
 21:18 SP: 4.0 PV: 4.2 DV: 0.2
 20:18 SP: 4.0 PV: 4.1 DV: 0.1
 19:18 SP: 4.0 PV: 4.2 DV: 0.2
 18:18 SP: 4.0 PV: 3.7 DV: -0.3
 17:18 SP: 4.0 PV: 4.4 DV: 0.4
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.5 DV: 0.5
 14:18 SP: 4.0 PV: 3.7 DV: -0.3
 13:18 SP: 4.0 PV: 4.4 DV: 0.4
 12:18 SP: 4.0 PV: 3.7 DV: -0.3
 11:18 SP: 4.0 PV: 4.4 DV: 0.4
 10:18 SP: 4.0 PV: 3.7 DV: -0.3
 09:18 SP: 4.0 PV: 4.4 DV: 0.4
 08:18 SP: 4.0 PV: 3.9 DV: -0.1
 07:18 SP: 4.0 PV: 4.6 DV: 0.6
 06:18 SP: 4.0 PV: 4.2 DV: 0.2
 05:18 SP: 4.0 PV: 4.6 DV: 0.6
 04:18 SP: 4.0 PV: 4.8 DV: 0.8
 03:18 SP: 4.0 PV: 3.9 DV: -0.1
 02:18 SP: 4.0 PV: 4.4 DV: 0.4
 01:18 SP: 4.0 PV: 4.7 DV: 0.7
 00:18 SP: 4.0 PV: 4.1 DV: 0.1

2022-11-16

23:18 SP: 4.0 PV: 4.6 DV: 0.6
 22:18 SP: 4.0 PV: 3.8 DV: -0.2
 21:18 SP: 4.0 PV: 4.5 DV: 0.5
 20:18 SP: 4.0 PV: 3.8 DV: -0.2
 19:18 SP: 4.0 PV: 4.5 DV: 0.5
 18:18 SP: 4.0 PV: 3.7 DV: -0.3
 17:18 SP: 4.0 PV: 4.4 DV: 0.4
 16:18 SP: 4.0 PV: 4.1 DV: 0.1
 15:18 SP: 4.0 PV: 4.0 DV: 0.0
 14:18 SP: 4.0 PV: 4.6 DV: 0.6

1

13:18 SP: 4.0 PV: 3.9 DV: -0.
 12:18 SP: 4.0 PV: 4.5 DV: 0.5
 11:18 SP: 4.0 PV: 4.0 DV: 0.0
 10:18 SP: 4.0 PV: 4.6 DV: 0.6
 09:18 SP: 4.0 PV: 3.8 DV: -0.2
 08:18 SP: 4.0 PV: 4.5 DV: 0.5
 07:18 SP: 4.0 PV: 3.8 DV: -0.2
 06:18 SP: 4.0 PV: 4.6 DV: 0.6
 05:18 SP: 4.0 PV: 3.8 DV: -0.2
 04:18 SP: 4.0 PV: 4.6 DV: 0.6
 03:18 SP: 4.0 PV: 3.9 DV: -0.1
 02:18 SP: 4.0 PV: 4.6 DV: 0.6
 01:18 SP: 4.0 PV: 3.8 DV: -0.2
 00:18 SP: 4.0 PV: 4.6 DV: 0.6

2022-11-15

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.4 DV: 0.4
 21:18 SP: 4.0 PV: 4.0 DV: 0.0
 20:18 SP: 4.0 PV: 4.2 DV: 0.2
 19:18 SP: 4.0 PV: 3.8 DV: -0.2
 18:18 SP: 4.0 PV: 4.3 DV: 0.3
 17:18 SP: 4.0 PV: 4.0 DV: 0.0
 16:18 SP: 4.0 PV: 4.2 DV: 0.2
 15:18 SP: 4.0 PV: 3.7 DV: -0.3
 14:18 SP: 4.0 PV: 4.4 DV: 0.4
 13:18 SP: 4.0 PV: 3.7 DV: -0.3
 12:18 SP: 4.0 PV: 4.4 DV: 0.4
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.5 DV: 0.5
 09:18 SP: 4.0 PV: 3.7 DV: -0.3
 08:18 SP: 4.0 PV: 4.6 DV: 0.6
 07:18 SP: 4.0 PV: 3.9 DV: -0.1
 06:18 SP: 4.0 PV: 4.2 DV: 0.2
 05:18 SP: 4.0 PV: 4.2 DV: 0.2
 04:18 SP: 4.0 PV: 4.2 DV: 0.2
 03:18 SP: 4.0 PV: 3.8 DV: -0.2
 02:18 SP: 4.0 PV: 4.3 DV: 0.3
 01:18 SP: 4.0 PV: 4.1 DV: 0.1
 00:18 SP: 4.0 PV: 3.8 DV: -0.2

2022-11-18

23:18 SP: 4.0 PV: 4.3 DV: 0.3
 22:18 SP: 4.0 PV: 3.7 DV: -0.3
 21:18 SP: 4.0 PV: 4.4 DV: 0.4
 20:18 SP: 4.0 PV: 3.7 DV: -0.3
 19:18 SP: 4.0 PV: 4.5 DV: 0.5
 18:18 SP: 4.0 PV: 3.7 DV: -0.3
 17:18 SP: 4.0 PV: 4.5 DV: 0.5
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.4 DV: 0.4
 14:18 SP: 4.0 PV: 3.7 DV: -0.3
 13:18 SP: 4.0 PV: 4.4 DV: 0.4
 12:18 SP: 4.0 PV: 3.9 DV: -0.1
 11:18 SP: 4.0 PV: 4.3 DV: 0.3
 10:18 SP: 4.0 PV: 4.2 DV: 0.2
 09:18 SP: 4.0 PV: 4.2 DV: 0.2
 08:18 SP: 4.0 PV: 4.2 DV: 0.2
 07:18 SP: 4.0 PV: 3.7 DV: -0.3
 06:18 SP: 4.0 PV: 4.4 DV: 0.4
 05:18 SP: 4.0 PV: 3.9 DV: -0.1
 04:18 SP: 4.0 PV: 4.2 DV: 0.2
 03:18 SP: 4.0 PV: 3.7 DV: -0.3
 02:18 SP: 4.0 PV: 4.3 DV: 0.3
 01:18 SP: 4.0 PV: 4.1 DV: 0.1
 00:18 SP: 4.0 PV: 4.2 DV: 0.2

2022-11-17

23:18 SP: 4.0 PV: 4.7 DV: 0.7
 22:18 SP: 4.0 PV: 4.7 DV: 0.7
 21:18 SP: 4.0 PV: 3.9 DV: -0.1
 20:18 SP: 4.0 PV: 4.3 DV: 0.3
 19:18 SP: 4.0 PV: 4.5 DV: 0.5
 18:18 SP: 4.0 PV: 4.7 DV: 0.7
 17:18 SP: 4.0 PV: 4.7 DV: 0.7
 16:18 SP: 4.0 PV: 4.7 DV: 0.7
 15:18 SP: 4.0 PV: 3.9 DV: -0.1
 14:18 SP: 4.0 PV: 4.3 DV: 0.3
 13:18 SP: 4.0 PV: 4.3 DV: 0.3
 12:18 SP: 4.0 PV: 4.5 DV: 0.5
 11:18 SP: 4.0 PV: 4.2 DV: 0.2
 10:18 SP: 4.0 PV: 4.5 DV: 0.5
 09:18 SP: 4.0 PV: 4.7 DV: 0.7
 08:18 SP: 4.0 PV: 4.8 DV: 0.8
 07:18 SP: 4.0 PV: 3.9 DV: -0.1
 06:18 SP: 4.0 PV: 4.4 DV: 0.4
 05:18 SP: 4.0 PV: 4.3 DV: 0.3
 04:18 SP: 4.0 PV: 4.6 DV: 0.6
 03:18 SP: 4.0 PV: 4.8 DV: 0.8
 02:18 SP: 4.0 PV: 3.9 DV: -0.1
 01:18 SP: 4.0 PV: 4.5 DV: 0.5
 00:18 SP: 4.0 PV: 4.2 DV: 0.2

2022-11-20

23:18 SP: 4.0 PV: 4.3 DV: 0.3
 22:18 SP: 4.0 PV: 3.7 DV: -0.3
 21:18 SP: 4.0 PV: 4.4 DV: 0.4
 20:18 SP: 4.0 PV: 3.7 DV: -0.3
 19:18 SP: 4.0 PV: 4.4 DV: 0.4
 18:18 SP: 4.0 PV: 4.0 DV: 0.0
 17:18 SP: 4.0 PV: 4.2 DV: 0.2
 16:18 SP: 4.0 PV: 4.2 DV: 0.2
 15:18 SP: 4.0 PV: 3.8 DV: -0.2
 14:18 SP: 4.0 PV: 4.3 DV: 0.3
 13:18 SP: 4.0 PV: 4.1 DV: 0.1
 12:18 SP: 4.0 PV: 4.2 DV: 0.2
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.3 DV: 0.3
 09:18 SP: 4.0 PV: 3.7 DV: -0.3
 08:18 SP: 4.0 PV: 4.4 DV: 0.4
 07:18 SP: 4.0 PV: 3.7 DV: -0.3
 06:18 SP: 4.0 PV: 4.6 DV: 0.6
 05:18 SP: 4.0 PV: 3.8 DV: -0.2
 04:18 SP: 4.0 PV: 4.6 DV: 0.6
 03:18 SP: 4.0 PV: 3.7 DV: -0.3
 02:18 SP: 4.0 PV: 4.3 DV: 0.3
 01:18 SP: 4.0 PV: 3.7 DV: -0.3
 00:18 SP: 4.0 PV: 4.4 DV: 0.4

2022-11-19

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 4.3 DV: 0.3
0

22:18 SP: 4.0 PV: 4.0 DV: 0.

21:18 SP: 4.0 PV: 4.2 DV: 0.2

20:18 SP: 4.0 PV: 4.1 DV: 0.1

19:18 SP: 4.0 PV: 3.7 DV: -0.3

18:18 SP: 4.0 PV: 4.3 DV: 0.3

17:18 SP: 4.0 PV: 3.9 DV: -0.1

16:18 SP: 4.0 PV: 4.2 DV: 0.2

15:18 SP: 4.0 PV: 3.7 DV: -0.3

14:18 SP: 4.0 PV: 4.4 DV: 0.4

13:18 SP: 4.0 PV: 3.7 DV: -0.3

12:18 SP: 4.0 PV: 4.3 DV: 0.3

3

11:18 SP: 4.0 PV: 3.7 DV: -0.

10:18 SP: 4.0 PV: 4.4 DV: 0.4

09:18 SP: 4.0 PV: 3.7 DV: -0.3

08:18 SP: 4.0 PV: 4.4 DV: 0.4

07:18 SP: 4.0 PV: 3.7 DV: -0.3

06:18 SP: 4.0 PV: 4.4 DV: 0.4

05:18 SP: 4.0 PV: 4.1 DV: 0.1

04:18 SP: 4.0 PV: 4.6 DV: 0.6

03:18 SP: 4.0 PV: 3.9 DV: -0.1

02:18 SP: 4.0 PV: 4.6 DV: 0.6

01:18 SP: 4.0 PV: 3.7 DV: -0.3

00:18 SP: 4.0 PV: 4.4 DV: 0.4

2022-11-22

23:18 SP: 4.0 PV: 4.1 DV: 0.1

22:18 SP: 4.0 PV: 4.6 DV: 0.6

21:18 SP: 4.0 PV: 3.7 DV: -0.3

20:18 SP: 4.0 PV: 4.4 DV: 0.4

19:18 SP: 4.0 PV: 4.2 DV: 0.2

18:18 SP: 4.0 PV: 4.6 DV: 0.6

17:18 SP: 4.0 PV: 3.8 DV: -0.2

16:18 SP: 4.0 PV: 4.5 DV: 0.5

15:18 SP: 4.0 PV: 4.6 DV: 0.6

14:18 SP: 4.0 PV: 3.8 DV: -0.2

13:18 SP: 4.0 PV: 4.4 DV: 0.4

12:18 SP: 4.0 PV: 4.6 DV: 0.6

11:18 SP: 4.0 PV: 3.7 DV: -0.3

10:18 SP: 4.0 PV: 4.3 DV: 0.3

09:18 SP: 4.0 PV: 4.2 DV: 0.2

08:18 SP: 4.0 PV: 4.5 DV: 0.5

07:18 SP: 4.0 PV: 3.9 DV: -0.1

06:18 SP: 4.0 PV: 4.6 DV: 0.6

05:18 SP: 4.0 PV: 3.7 DV: -0.3

4

04:18 SP: 4.0 PV: 4.4 DV: 0.

03:18 SP: 4.0 PV: 3.7 DV: -0.3

02:18 SP: 4.0 PV: 4.3 DV: 0.3

01:18 SP: 4.0 PV: 4.2 DV: 0.2

00:18 SP: 4.0 PV: 4.6 DV: 0.6

2022-11-21

23:18 SP: 4.0 PV: 4.1 DV: 0.1

22:18 SP: 4.0 PV: 3.7 DV: -0.3

21:18 SP: 4.0 PV: 4.4 DV: 0.4

20:18 SP: 4.0 PV: 3.9 DV: -0.1

19:18 SP: 4.0 PV: 3.8 DV: -0.2

18:18 SP: 4.0 PV: 4.4 DV: 0.4

17:18 SP: 4.0 PV: 4.0 DV: 0.0

16:18 SP: 4.0 PV: 4.2 DV: 0.2

15:18 SP: 4.0 PV: 4.1 DV: 0.1

14:18 SP: 4.0 PV: 3.7 DV: -0.3

13:18 SP: 4.0 PV: 4.4 DV: 0.4

12:18 SP: 4.0 PV: 4.0 DV: 0.0

11:18 SP: 4.0 PV: 3.8 DV: -0.2

10:18 SP: 4.0 PV: 4.3 DV: 0.3

09:18 SP: 4.0 PV: 4.1 DV: 0.1

08:18 SP: 4.0 PV: 4.6 DV: 0.6

07:18 SP: 4.0 PV: 3.8 DV: -0.2

06:18 SP: 4.0 PV: 4.5 DV: 0.5

05:18 SP: 4.0 PV: 4.2 DV: 0.2

04:18 SP: 4.0 PV: 4.6 DV: 0.6

03:18 SP: 4.0 PV: 3.9 DV: -0.1

02:18 SP: 4.0 PV: 4.6 DV: 0.6

01:18 SP: 4.0 PV: 3.7 DV: -0.3

00:18 SP: 4.0 PV: 4.4 DV: 0.4

2022-11-24

23:18 SP: 4.0 PV: 3.9 DV: -0.1

22:18 SP: 4.0 PV: 4.2 DV: 0.2

.1

21:18 SP: 4.0 PV: 4.1 DV: 0

20:18 SP: 4.0 PV: 3.7 DV: -0.3

19:18 SP: 4.0 PV: 4.4 DV: 0.4

18:18 SP: 4.0 PV: 3.8 DV: -0.2

17:18 SP: 4.0 PV: 3.8 DV: -0.2

16:18 SP: 4.0 PV: 4.3 DV: 0.3

15:18 SP: 4.0 PV: 3.7 DV: -0.3

14:18 SP: 4.0 PV: 4.5 DV: 0.5

13:18 SP: 4.0 PV: 5.1 DV: 1.1

12:18 SP: 4.0 PV: 3.7 DV: -0.3

11:18 SP: 4.0 PV: 4.8 DV: 0.8

10:18 SP: 4.0 PV: 4.0 DV: 0.0

09:18 SP: 4.0 PV: 3.8 DV: -0.2

08:18 SP: 4.0 PV: 4.3 DV: 0.3

07:18 SP: 4.0 PV: 3.9 DV: -0.1

06:18 SP: 4.0 PV: 3.9 DV: -0.1

05:18 SP: 4.0 PV: 4.3 DV: 0.3

04:18 SP: 4.0 PV: 3.9 DV: -0.1

03:18 SP: 4.0 PV: 3.8 DV: -0.2

02:18 SP: 4.0 PV: 4.4 DV: 0.4

01:18 SP: 4.0 PV: 3.8 DV: -0.2

00:18 SP: 4.0 PV: 3.8 DV: -0.2

2022-11-23

SP Setting Point
PV Present Value
DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 3.9 DV: -0.1
 22:18 SP: 4.0 PV: 4.3 DV: 0.3
 21:18 SP: 4.0 PV: 4.0 DV: 0.0
 20:18 SP: 4.0 PV: 3.7 DV: -0.3
 19:18 SP: 4.0 PV: 4.4 DV: 0.4
 18:18 SP: 4.0 PV: 3.7 DV: -0.3
 17:18 SP: 4.0 PV: 4.3 DV: 0.3
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.5 DV: 0.5
 14:18 SP: 4.0 PV: 3.7 DV: -0.3
 13:18 SP: 4.0 PV: 4.3 DV: 0.3
 12:18 SP: 4.0 PV: 4.0 DV: 0.0
 11:18 SP: 4.0 PV: 3.8 DV: -0.2
 10:18 SP: 4.0 PV: 4.3 DV: 0.3
 09:18 SP: 4.0 PV: 3.7 DV: -0.3
 08:18 SP: 4.0 PV: 4.5 DV: 0.5
 07:18 SP: 4.0 PV: 3.9 DV: -0.1
 06:18 SP: 4.0 PV: 4.3 DV: 0.3
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.4 DV: 0.4
 03:18 SP: 4.0 PV: 3.9 DV: -0.1
 02:18 SP: 4.0 PV: 3.8 DV: -0.2
 01:18 SP: 4.0 PV: 4.3 DV: 0.3
 00:18 SP: 4.0 PV: 4.0 DV: 0.0

2022-11-26

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.4 DV: 0.4
 21:18 SP: 4.0 PV: 3.7 DV: -0.3
 20:18 SP: 4.0 PV: 4.3 DV: 0.3
 19:18 SP: 4.0 PV: 4.1 DV: 0.1

3

18:18 SP: 4.0 PV: 3.7 DV: -0.1
 17:18 SP: 4.0 PV: 4.5 DV: 0.5
 16:18 SP: 4.0 PV: 3.8 DV: -0.2
 15:18 SP: 4.0 PV: 4.2 DV: 0.2
 14:18 SP: 4.0 PV: 4.1 DV: 0.1
 13:18 SP: 4.0 PV: 3.7 DV: -0.3
 12:18 SP: 4.0 PV: 4.4 DV: 0.4
 11:18 SP: 4.0 PV: 3.9 DV: -0.1
 10:18 SP: 4.0 PV: 4.2 DV: 0.2
 09:18 SP: 4.0 PV: 3.7 DV: -0.3
 08:18 SP: 4.0 PV: 4.3 DV: 0.3
 07:18 SP: 4.0 PV: 4.0 DV: 0.0
 06:18 SP: 4.0 PV: 3.9 DV: -0.1
 05:18 SP: 4.0 PV: 4.3 DV: 0.3
 04:18 SP: 4.0 PV: 4.0 DV: 0.0
 03:18 SP: 4.0 PV: 3.7 DV: -0.3
 02:18 SP: 4.0 PV: 4.4 DV: 0.4
 01:18 SP: 4.0 PV: 3.9 DV: -0.1
 00:18 SP: 4.0 PV: 4.2 DV: 0.2

2022-11-25

23:18 SP: 4.0 PV: 4.3 DV: 0.3
 22:18 SP: 4.0 PV: 4.2 DV: 0.2
 21:18 SP: 4.0 PV: 4.6 DV: 0.6
 20:18 SP: 4.0 PV: 3.9 DV: -0.1
 19:18 SP: 4.0 PV: 4.5 DV: 0.5
 18:18 SP: 4.0 PV: 3.7 DV: -0.3

3

17:18 SP: 4.0 PV: 4.3 DV: 0.1
 16:18 SP: 4.0 PV: 4.2 DV: 0.2
 15:18 SP: 4.0 PV: 4.6 DV: 0.6
 14:18 SP: 4.0 PV: 3.9 DV: -0.1
 13:18 SP: 4.0 PV: 4.4 DV: 0.4
 12:18 SP: 4.0 PV: 4.1 DV: 0.1
 11:18 SP: 4.0 PV: 4.3 DV: 0.3
 10:18 SP: 4.0 PV: 3.9 DV: -0.1
 09:18 SP: 4.0 PV: 4.2 DV: 0.2
 08:18 SP: 4.0 PV: 3.7 DV: -0.3
 07:18 SP: 4.0 PV: 4.4 DV: 0.4
 06:18 SP: 4.0 PV: 3.7 DV: -0.3
 05:18 SP: 4.0 PV: 4.4 DV: 0.4
 04:18 SP: 4.0 PV: 3.7 DV: -0.3
 03:18 SP: 4.0 PV: 4.4 DV: 0.4
 02:18 SP: 4.0 PV: 3.7 DV: -0.3
 01:18 SP: 4.0 PV: 4.4 DV: 0.4
 00:18 SP: 4.0 PV: 3.8 DV: -0.2

2022-11-28

23:18 SP: 4.0 PV: 3.9 DV: -0.1
 22:18 SP: 4.0 PV: 4.4 DV: 0.4

2

*21:18 SP: 4.0 PV: 3.8 DV: -0.1
 20:18 SP: 4.0 PV: 3.8 DV: -0.2
 19:18 SP: 4.0 PV: 4.4 DV: 0.4
 18:18 SP: 4.0 PV: 3.8 DV: -0.2
 17:18 SP: 4.0 PV: 3.8 DV: -0.2
 16:18 SP: 4.0 PV: 4.4 DV: 0.4
 15:18 SP: 4.0 PV: 3.9 DV: -0.1
 14:18 SP: 4.0 PV: 3.9 DV: -0.1
 13:18 SP: 4.0 PV: 4.3 DV: 0.3
 12:18 SP: 4.0 PV: 3.9 DV: -0.1
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.4 DV: 0.4
 09:18 SP: 4.0 PV: 3.8 DV: -0.2
 08:18 SP: 4.0 PV: 3.8 DV: -0.2
 07:18 SP: 4.0 PV: 4.4 DV: 0.4
 06:18 SP: 4.0 PV: 3.7 DV: -0.3
 05:18 SP: 4.0 PV: 3.8 DV: -0.2
 04:18 SP: 4.0 PV: 4.3 DV: 0.3
 03:18 SP: 4.0 PV: 4.0 DV: 0.0
 02:18 SP: 4.0 PV: 3.8 DV: -0.2
 01:18 SP: 4.0 PV: 4.4 DV: 0.4
 00:18 SP: 4.0 PV: 3.9 DV: -0.1

2022-11-27

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2022.11

23:18 SP: 4.0 PV: 3.8 DV: -0.2
 22:18 SP: 4.0 PV: 4.2 DV: 0.2
 21:18 SP: 4.0 PV: 4.1 DV: 0.1
 20:18 SP: 4.0 PV: 3.8 DV: -0.2
 19:18 SP: 4.0 PV: 4.3 DV: 0.3
 18:18 SP: 4.0 PV: 4.1 DV: 0.1
 17:18 SP: 4.0 PV: 4.2 DV: 0.2
 16:18 SP: 4.0 PV: 3.7 DV: -0.3
 15:18 SP: 4.0 PV: 4.3 DV: 0.3
 14:18 SP: 4.0 PV: 4.2 DV: 0.2
 13:18 SP: 4.0 PV: 4.2 DV: 0.2
 12:18 SP: 4.0 PV: 3.8 DV: -0.2
 11:18 SP: 4.0 PV: 4.3 DV: 0.3

7

10:18 SP: 4.0 PV: 4.7 DV: 0.
 09:18 SP: 4.0 PV: 3.8 DV: -0.2
 08:18 SP: 4.0 PV: 4.3 DV: 0.3
 07:18 SP: 4.0 PV: 4.2 DV: 0.2
 06:18 SP: 4.0 PV: 4.2 DV: 0.2
 05:18 SP: 4.0 PV: 3.9 DV: -0.1
 04:18 SP: 4.0 PV: 4.3 DV: 0.3
 03:18 SP: 4.0 PV: 4.0 DV: 0.0
 02:18 SP: 4.0 PV: 4.2 DV: 0.2
 01:18 SP: 4.0 PV: 3.7 DV: -0.3
 00:18 SP: 4.0 PV: 4.4 DV: 0.4

2022-11-30

23:18 SP: 4.0 PV: 3.7 DV: -0.3
 22:18 SP: 4.0 PV: 4.5 DV: 0.5
 21:18 SP: 4.0 PV: 3.8 DV: -0.2

5

*20:18 SP: 4.0 PV: 4.5 DV: 0.
 19:18 SP: 4.0 PV: 3.7 DV: -0.3
 18:18 SP: 4.0 PV: 4.5 DV: 0.5
 17:18 SP: 4.0 PV: 4.0 DV: 0.0
 16:18 SP: 4.0 PV: 4.6 DV: 0.6
 15:18 SP: 4.0 PV: 4.0 DV: 0.0
 14:18 SP: 4.0 PV: 4.6 DV: 0.6
 13:18 SP: 4.0 PV: 4.1 DV: 0.1
 12:18 SP: 4.0 PV: 4.6 DV: 0.6
 11:18 SP: 4.0 PV: 3.7 DV: -0.3
 10:18 SP: 4.0 PV: 4.4 DV: 0.4
 09:18 SP: 4.0 PV: 4.2 DV: 0.2
 08:18 SP: 4.0 PV: 4.6 DV: 0.6
 07:18 SP: 4.0 PV: 3.8 DV: -0.2
 06:18 SP: 4.0 PV: 4.4 DV: 0.4
 05:18 SP: 4.0 PV: 3.7 DV: -0.3
 04:18 SP: 4.0 PV: 4.3 DV: 0.3
 03:18 SP: 4.0 PV: 4.6 DV: 0.6
 02:18 SP: 4.0 PV: 3.8 DV: -0.2
 01:18 SP: 4.0 PV: 4.5 DV: 0.5
 00:18 SP: 4.0 PV: 3.7 DV: -0.3

2022-11-29

SP Setting Point
 PV Present Value
 DV Difference Value

8 of 8

date of copying

sign