

IP STORAGE TEMPERATURE LOG

Storage Subject	Description	약품냉장고	Storage Space	냉장고 9134Room
	Manufacturer	Giant Star	Storage Period	2025.9
	Model Name	CBR1000SS	Temperature Range	2~8℃
	Serial Number	GS17090102-10	Setting Point	4.0℃
Calibration Subject	Description	Digital Thermometer	Min/Max Record	온도기록 후 reset하여 그 시점 이후 Min/Max 새로 기록됨
	Manufacturer	SATO		
	Model Name	PC-3500		
	Serial Number	833780		
	Date of Calibration	2025.2.25	Alarm Range	<2℃, >8℃, 5분 후
	Date of Calibration Due	2026.2.25	Alarm Method	Call to Pharmacist
	Certificate No.	SC2502-05400-7	Alarm Clear	000

Date	Time	Temperature(℃)			Verified by	Comment
		Min	Max	Current		
2025.09.01	P:30	2	5	4	ant	
2025.09.02	P:30	3	5	3	ant	
2025.09.03	P:30	3	5	4	ant	
2025.09.04	P:30	3	5	3	ant	
2025.09.05	P:40	3	5	4	ant	
2025.09.06						
2025.09.07						
2025.09.08	P:00	3	5	4	ant	
2025.09.09	P:30	3	5	3	ant	
2025.09.10	P:30	3	5	3	ant	
2025.09.11	P:30	3	5	3	ant	
2025.09.12	P:30	2	5	3	ant	
2025.09.13						
2025.09.14						
2025.09.15	P:30	2	5	3	ant	
2025.09.16	P:40	2	5	4	ant	
2025.09.17	P:30	2	5	5	ant	
2025.09.18	P:20	3	5	4	ant	
2025.09.19	P:20	2	5	4	ant	
2025.09.20						
2025.09.21						
2025.09.22	P:30	3	5	5	ant	
2025.09.23	P:30	3	5	5	ant	
2025.09.24	P:30	3	5	3	ant	
2025.09.25	P:20	3	5	3	ant	
2025.09.26	P:10	3	5	3	ant	
2025.09.27						
2025.09.28						
2025.09.29	P:30	2	5	5	ant	
2025.09.30	P:40	2	5	5	ant	14.4 IP 27.48.22

date of copying

sign

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 4.2 DV: 0.2
 21:24 SP: 4.0 PV: 3.8 DV: -0.2
 20:24 SP: 4.0 PV: 3.7 DV: -0.3
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 4.8 DV: 0.8
 16:24 SP: 4.0 PV: 4.6 DV: 0.6
 15:24 SP: 4.0 PV: 4.3 DV: 0.3
 14:24 SP: 4.0 PV: 3.8 DV: -0.2
 13:24 SP: 4.0 PV: 3.6 DV: -0.4
 12:24 SP: 4.0 PV: 3.6 DV: -0.4
 11:24 SP: 4.0 PV: 4.7 DV: 0.7
 10:24 SP: 4.0 PV: 4.7 DV: 0.7
 09:24 SP: 4.0 PV: 4.3 DV: 0.3
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 4.2 DV: 0.2
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.6 DV: -0.4
 04:24 SP: 4.0 PV: 4.3 DV: 0.3
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 4.2 DV: 0.2
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 3.6 DV: -0.4

2025-09-02

23:24 SP: 4.0 PV: 4.4 DV: 0.4
 22:24 SP: 4.0 PV: 4.8 DV: 0.8
 21:24 SP: 4.0 PV: 4.4 DV: 0.4
 20:24 SP: 4.0 PV: 3.9 DV: -0.1

4

19:24 SP: 4.0 PV: 3.6 DV: -0.1
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 4.3 DV: 0.3

2

16:24 SP: 4.0 PV: 3.8 DV: -0.1
 15:24 SP: 4.0 PV: 4.2 DV: 0.2
 14:24 SP: 4.0 PV: 3.8 DV: -0.2
 13:24 SP: 4.0 PV: 4.3 DV: 0.3
 12:24 SP: 4.0 PV: 3.6 DV: -0.4
 11:24 SP: 4.0 PV: 3.6 DV: -0.4

Condensor1 Temp#1. OK...

Compressor#1 Output OK...

System Checking Process...

10:24:51

2025-09-01

주소창에 한글로 혈액냉장고

www.gsmedical.co.kr

CBR-1000SS

GIANT STAR Ltd.

09:49 SP: 4.0 PV: 3.8 DV: -0.2
 08:49 SP: 4.0 PV: 4.0 DV: 0.0
 07:49 SP: 4.0 PV: 3.7 DV: -0.3
 06:49 SP: 4.0 PV: 3.7 DV: -0.3
 05:49 SP: 4.0 PV: 3.4 DV: -0.6
 04:49 SP: 4.0 PV: 3.8 DV: -0.2
 03:49 SP: 4.0 PV: 4.8 DV: 0.8
 02:49 SP: 4.0 PV: 4.5 DV: 0.5
 01:49 SP: 4.0 PV: 4.3 DV: 0.3
 00:49 SP: 4.0 PV: 3.8 DV: -0.2
 2025-09-01

23:24 SP: 4.0 PV: 3.9 DV: -0.1
 22:24 SP: 4.0 PV: 3.9 DV: -0.1
 21:24 SP: 4.0 PV: 3.8 DV: -0.2
 20:24 SP: 4.0 PV: 3.9 DV: -0.1
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 4.2 DV: 0.2
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 4.0 DV: 0.0
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 4.1 DV: 0.1
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 4.1 DV: 0.1
 10:24 SP: 4.0 PV: 3.7 DV: -0.3
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 3.6 DV: -0.4
 07:24 SP: 4.0 PV: 4.2 DV: 0.2
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 4.0 DV: 0.0
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 4.0 DV: 0.0
 02:24 SP: 4.0 PV: 3.9 DV: -0.1

0

01:24 SP: 4.0 PV: 4.0 DV: 0.1
 00:24 SP: 4.0 PV: 4.0 DV: 0.0

2025-09-04

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 4.2 DV: 0.2
 21:24 SP: 4.0 PV: 3.8 DV: -0.2
 20:24 SP: 4.0 PV: 4.1 DV: 0.1
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 4.0 DV: 0.0
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 4.1 DV: 0.1
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 4.1 DV: 0.1
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 3.6 DV: -0.4
 10:24 SP: 4.0 PV: 3.6 DV: -0.4
 09:24 SP: 4.0 PV: 3.8 DV: -0.2
 08:24 SP: 4.0 PV: 4.2 DV: 0.2
 07:24 SP: 4.0 PV: 3.9 DV: -0.1
 06:24 SP: 4.0 PV: 4.0 DV: 0.0
 05:24 SP: 4.0 PV: 3.7 DV: -0.3
 04:24 SP: 4.0 PV: 4.2 DV: 0.2
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.6 DV: -0.4
 01:24 SP: 4.0 PV: 4.3 DV: 0.3
 00:24 SP: 4.0 PV: 3.8 DV: -0.2

2025-09-03

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.9 DV: -0.1
 22:24 SP: 4.0 PV: 4.0 DV: 0.0
 21:24 SP: 4.0 PV: 3.7 DV: -0.3
 20:24 SP: 4.0 PV: 4.2 DV: 0.2
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 4.1 DV: 0.1
 17:24 SP: 4.0 PV: 3.7 DV: -0.3
 16:24 SP: 4.0 PV: 4.1 DV: 0.1
 15:24 SP: 4.0 PV: 3.8 DV: -0.2
 14:24 SP: 4.0 PV: 4.1 DV: 0.1
 13:24 SP: 4.0 PV: 3.7 DV: -0.3
 12:24 SP: 4.0 PV: 4.2 DV: 0.2
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.6 DV: -0.4
 09:24 SP: 4.0 PV: 4.2 DV: 0.2
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 3.7 DV: -0.3
 06:24 SP: 4.0 PV: 3.4 DV: -0.6
 05:24 SP: 4.0 PV: 4.2 DV: 0.2
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 4.0 DV: 0.0
 02:24 SP: 4.0 PV: 3.8 DV: -0.2
 01:24 SP: 4.0 PV: 3.6 DV: -0.4
 00:24 SP: 4.0 PV: 4.2 DV: 0.2
 2025-09-06
 23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 3.6 DV: -0.4
 21:24 SP: 4.0 PV: 4.3 DV: 0.3
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.9 DV: -0.1
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 3.6 DV: -0.4
 16:24 SP: 4.0 PV: 3.6 DV: -0.4
 15:24 SP: 4.0 PV: 3.6 DV: -0.4
 14:24 SP: 4.0 PV: 4.7 DV: 0.7
 13:24 SP: 4.0 PV: 4.6 DV: 0.6
 12:24 SP: 4.0 PV: 4.3 DV: 0.3
 11:24 SP: 4.0 PV: 3.8 DV: -0.2
 10:24 SP: 4.0 PV: 3.8 DV: -0.2
 09:24 SP: 4.0 PV: 4.1 DV: 0.1
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 4.1 DV: 0.1
 06:24 SP: 4.0 PV: 4.0 DV: 0.0
 05:24 SP: 4.0 PV: 3.7 DV: -0.3
 04:24 SP: 4.0 PV: 4.1 DV: 0.1
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 4.2 DV: 0.2
 01:24 SP: 4.0 PV: 3.8 DV: -0.2
 00:24 SP: 4.0 PV: 4.0 DV: 0.0
 2025-09-05

23:24 SP: 4.0 PV: 3.8 DV: -0.2
 22:24 SP: 4.0 PV: 3.6 DV: -0.4
 21:24 SP: 4.0 PV: 3.6 DV: -0.4
 20:24 SP: 4.0 PV: 4.4 DV: 0.4
 19:24 SP: 4.0 PV: 4.8 DV: 0.8
 18:24 SP: 4.0 PV: 4.4 DV: 0.4
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 3.6 DV: -0.4
 15:24 SP: 4.0 PV: 4.3 DV: 0.3
 14:24 SP: 4.0 PV: 3.8 DV: -0.2
 13:24 SP: 4.0 PV: 4.2 DV: 0.2
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 3.6 DV: -0.4
 10:24 SP: 4.0 PV: 4.2 DV: 0.2
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.7 DV: -0.3
 07:24 SP: 4.0 PV: 4.2 DV: 0.2
 06:24 SP: 4.0 PV: 3.8 DV: -0.2
 05:24 SP: 4.0 PV: 4.1 DV: 0.1
 04:24 SP: 4.0 PV: 3.9 DV: -0.1
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 4.1 DV: 0.1
 01:24 SP: 4.0 PV: 3.8 DV: -0.2
 00:24 SP: 4.0 PV: 3.7 DV: -0.3
 2025-09-08
 23:24 SP: 4.0 PV: 4.2 DV: 0.2
 22:24 SP: 4.0 PV: 3.7 DV: -0.3
 21:24 SP: 4.0 PV: 4.2 DV: 0.2
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 4.0 DV: 0.0
 18:24 SP: 4.0 PV: 4.1 DV: 0.1
 17:24 SP: 4.0 PV: 3.9 DV: -0.1
 16:24 SP: 4.0 PV: 3.7 DV: -0.3
 15:24 SP: 4.0 PV: 4.2 DV: 0.2
 14:24 SP: 4.0 PV: 3.9 DV: -0.1
 13:24 SP: 4.0 PV: 3.6 DV: -0.4
 12:24 SP: 4.0 PV: 4.2 DV: 0.2
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 4.2 DV: 0.2
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 4.2 DV: 0.2
 07:24 SP: 4.0 PV: 3.8 DV: -0.2
 06:24 SP: 4.0 PV: 3.6 DV: -0.4
 05:24 SP: 4.0 PV: 4.3 DV: 0.3
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 3.6 DV: -0.4
 01:24 SP: 4.0 PV: 3.6 DV: -0.4
 00:24 SP: 4.0 PV: 4.2 DV: 0.2
 2025-09-07

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 4.0 DV: 0.0
 22:24 SP: 4.0 PV: 3.9 DV: -0.1
 21:24 SP: 4.0 PV: 3.7 DV: -0.3
 20:24 SP: 4.0 PV: 3.7 DV: -0.3
 19:24 SP: 4.0 PV: 4.2 DV: 0.2
 18:24 SP: 4.0 PV: 3.9 DV: -0.1
 17:24 SP: 4.0 PV: 3.6 DV: -0.4
 16:24 SP: 4.0 PV: 4.2 DV: 0.2
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 4.1 DV: 0.1
 13:24 SP: 4.0 PV: 3.7 DV: -0.3
 12:24 SP: 4.0 PV: 4.3 DV: 0.3
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 4.1 DV: 0.1
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.7 DV: -0.3
 07:24 SP: 4.0 PV: 4.2 DV: 0.2
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.7 DV: -0.3
 04:24 SP: 4.0 PV: 4.2 DV: 0.2
 03:24 SP: 4.0 PV: 4.0 DV: 0.0
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 4.0 DV: 0.0

2025-09-10

23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 3.7 DV: -0.3
 21:24 SP: 4.0 PV: 4.2 DV: 0.2
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 3.7 DV: -0.3
 16:24 SP: 4.0 PV: 4.6 DV: 0.6
 15:24 SP: 4.0 PV: 4.7 DV: 0.7
 14:24 SP: 4.0 PV: 4.4 DV: 0.4
 13:24 SP: 4.0 PV: 4.1 DV: 0.1
 12:24 SP: 4.0 PV: 3.8 DV: -0.2
 11:24 SP: 4.0 PV: 3.7 DV: -0.3
 10:24 SP: 4.0 PV: 4.2 DV: 0.2

2

09:24 SP: 4.0 PV: 3.8 DV: -0.1
 08:24 SP: 4.0 PV: 4.1 DV: 0.1
 07:24 SP: 4.0 PV: 4.0 DV: 0.0
 06:24 SP: 4.0 PV: 3.7 DV: -0.3
 05:24 SP: 4.0 PV: 4.2 DV: 0.2
 04:24 SP: 4.0 PV: 3.7 DV: -0.3
 03:24 SP: 4.0 PV: 4.1 DV: 0.1
 02:24 SP: 4.0 PV: 3.8 DV: -0.2
 01:24 SP: 4.0 PV: 3.9 DV: -0.1
 00:24 SP: 4.0 PV: 3.9 DV: -0.1

2025-09-09

23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 4.0 DV: 0.0
 21:24 SP: 4.0 PV: 3.8 DV: -0.2
 20:24 SP: 4.0 PV: 3.9 DV: -0.1
 19:24 SP: 4.0 PV: 3.9 DV: -0.1
 18:24 SP: 4.0 PV: 3.9 DV: -0.1
 17:24 SP: 4.0 PV: 3.7 DV: -0.3

4

16:24 SP: 4.0 PV: 3.6 DV: -0.1
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 3.7 DV: -0.3
 13:24 SP: 4.0 PV: 3.6 DV: -0.4
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 3.7 DV: -0.3
 10:24 SP: 4.0 PV: 3.7 DV: -0.3
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 3.7 DV: -0.3
 07:24 SP: 4.0 PV: 3.7 DV: -0.3
 06:24 SP: 4.0 PV: 3.7 DV: -0.3
 05:24 SP: 4.0 PV: 3.7 DV: -0.3
 04:24 SP: 4.0 PV: 3.7 DV: -0.3
 03:24 SP: 4.0 PV: 3.6 DV: -0.4
 02:24 SP: 4.0 PV: 3.6 DV: -0.4
 01:24 SP: 4.0 PV: 3.6 DV: -0.4
 00:24 SP: 4.0 PV: 3.6 DV: -0.4

2025-09-12

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 3.6 DV: -0.4
 21:24 SP: 4.0 PV: 3.6 DV: -0.4
 20:24 SP: 4.0 PV: 3.6 DV: -0.4
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 3.6 DV: -0.4
 16:24 SP: 4.0 PV: 3.6 DV: -0.4
 15:24 SP: 4.0 PV: 4.2 DV: 0.2
 14:24 SP: 4.0 PV: 3.9 DV: -0.1
 13:24 SP: 4.0 PV: 3.7 DV: -0.3
 12:24 SP: 4.0 PV: 4.2 DV: 0.2
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.9 DV: -0.1
 09:24 SP: 4.0 PV: 4.1 DV: 0.1
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 3.7 DV: -0.3
 06:24 SP: 4.0 PV: 4.2 DV: 0.2
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 4.1 DV: 0.1
 03:24 SP: 4.0 PV: 3.9 DV: -0.1
 02:24 SP: 4.0 PV: 3.7 DV: -0.3
 01:24 SP: 4.0 PV: 4.1 DV: 0.1
 00:24 SP: 4.0 PV: 3.9 DV: -0.1

2025-09-11

2025-09-11

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 3.7 DV: -0.3

4

21:24 SP: 4.0 PV: 3.6 DV: -0.4
 20:24 SP: 4.0 PV: 3.7 DV: -0.3
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 3.9 DV: -0.1
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.8 DV: -0.2
 14:24 SP: 4.0 PV: 3.8 DV: -0.2
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 3.9 DV: -0.1
 11:24 SP: 4.0 PV: 3.8 DV: -0.2
 10:24 SP: 4.0 PV: 3.7 DV: -0.3
 09:24 SP: 4.0 PV: 4.2 DV: 0.2
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.8 DV: -0.2
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 3.7 DV: -0.3
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 3.6 DV: -0.4

2025-09-14

23:24 SP: 4.0 PV: 3.6 DV: -0.4

4

22:24 SP: 4.0 PV: 3.6 DV: -0.4
 21:24 SP: 4.0 PV: 3.6 DV: -0.4
 20:24 SP: 4.0 PV: 3.7 DV: -0.3
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 3.9 DV: -0.1
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 4.1 DV: 0.1
 13:24 SP: 4.0 PV: 3.8 DV: -0.2
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 4.0 DV: 0.0
 10:24 SP: 4.0 PV: 3.8 DV: -0.2
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 3.7 DV: -0.3
 07:24 SP: 4.0 PV: 3.7 DV: -0.3
 06:24 SP: 4.0 PV: 4.1 DV: 0.1
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 3.9 DV: -0.1
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 4.0 DV: 0.0

2025-09-13

23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 4.1 DV: 0.1
 21:24 SP: 4.0 PV: 3.8 DV: -0.2
 20:24 SP: 4.0 PV: 3.7 DV: -0.3
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 4.2 DV: 0.2
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 4.2 DV: 0.2
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 4.0 DV: 0.0
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 3.8 DV: -0.2
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.8 DV: -0.2
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 4.0 DV: 0.0
 07:24 SP: 4.0 PV: 3.8 DV: -0.2
 06:24 SP: 4.0 PV: 3.7 DV: -0.3
 05:24 SP: 4.0 PV: 4.1 DV: 0.1
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 4.1 DV: 0.1
 01:24 SP: 4.0 PV: 3.9 DV: -0.1
 00:24 SP: 4.0 PV: 3.8 DV: -0.2

2025-09-16

23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 3.7 DV: -0.3
 21:24 SP: 4.0 PV: 3.6 DV: -0.4
 20:24 SP: 4.0 PV: 3.6 DV: -0.4
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 3.7 DV: -0.3
 16:24 SP: 4.0 PV: 3.7 DV: -0.3
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 3.7 DV: -0.3
 13:24 SP: 4.0 PV: 3.8 DV: -0.2
 12:24 SP: 4.0 PV: 3.9 DV: -0.1
 11:24 SP: 4.0 PV: 3.8 DV: -0.2
 10:24 SP: 4.0 PV: 3.8 DV: -0.2
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 3.7 DV: -0.3
 07:24 SP: 4.0 PV: 3.6 DV: -0.4
 06:24 SP: 4.0 PV: 3.6 DV: -0.4
 05:24 SP: 4.0 PV: 3.7 DV: -0.3
 04:24 SP: 4.0 PV: 3.7 DV: -0.3
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 3.7 DV: -0.3
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 3.7 DV: -0.3

2025-09-15

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 3.7 DV: -0.3
 21:24 SP: 4.0 PV: 3.7 DV: -0.3
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.8 DV: -0.2
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.8 DV: -0.2
 14:24 SP: 4.0 PV: 4.0 DV: 0.0
 13:24 SP: 4.0 PV: 4.0 DV: 0.0
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 4.2 DV: 0.2
 10:24 SP: 4.0 PV: 3.9 DV: -0.1
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.7 DV: -0.3
 06:24 SP: 4.0 PV: 3.7 DV: -0.3
 05:24 SP: 4.0 PV: 3.6 DV: -0.4
 04:24 SP: 4.0 PV: 3.7 DV: -0.3
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.8 DV: -0.2
 00:24 SP: 4.0 PV: 3.7 DV: -0.3
 2025-09-18
 23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 3.6 DV: -0.4
 21:24 SP: 4.0 PV: 3.7 DV: -0.3
 20:24 SP: 4.0 PV: 3.6 DV: -0.4
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 3.6 DV: -0.4
 16:24 SP: 4.0 PV: 3.6 DV: -0.4
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 3.9 DV: -0.1
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 3.8 DV: -0.2
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.9 DV: -0.1
 09:24 SP: 4.0 PV: 4.0 DV: 0.0
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.9 DV: -0.1
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.9 DV: -0.1
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 3.9 DV: -0.1
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.9 DV: -0.1
 00:24 SP: 4.0 PV: 3.8 DV: -0.2
 2025-09-17

23:24 SP: 4.0 PV: 3.8 DV: -0.2
 22:24 SP: 4.0 PV: 3.9 DV: -0.1
 21:24 SP: 4.0 PV: 3.8 DV: -0.2
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.8 DV: -0.2
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 4.1 DV: 0.1
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.8 DV: -0.2
 14:24 SP: 4.0 PV: 3.7 DV: -0.3
 13:24 SP: 4.0 PV: 3.8 DV: -0.2
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 3.7 DV: -0.3
 10:24 SP: 4.0 PV: 3.7 DV: -0.3
 09:24 SP: 4.0 PV: 3.8 DV: -0.2
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.8 DV: -0.2
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 4.0 DV: 0.0
 04:24 SP: 4.0 PV: 3.9 DV: -0.1
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.8 DV: -0.2
 01:24 SP: 4.0 PV: 3.9 DV: -0.1
 00:24 SP: 4.0 PV: 3.8 DV: -0.2
 2025-09-20
 23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 4.0 DV: 0.0
 21:24 SP: 4.0 PV: 3.7 DV: -0.3
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.8 DV: -0.2
 18:24 SP: 4.0 PV: 3.9 DV: -0.1
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 4.0 DV: 0.0
 13:24 SP: 4.0 PV: 3.7 DV: -0.3
 12:24 SP: 4.0 PV: 4.1 DV: 0.1
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.9 DV: -0.1
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.9 DV: -0.1
 06:24 SP: 4.0 PV: 3.8 DV: -0.2
 05:24 SP: 4.0 PV: 4.1 DV: 0.1
 04:24 SP: 4.0 PV: 3.9 DV: -0.1
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.7 DV: -0.3
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 3.6 DV: -0.4
 2025-09-19

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.8 DV: -0.2
 22:24 SP: 4.0 PV: 4.0 DV: 0.0
 21:24 SP: 4.0 PV: 3.9 DV: -0.1
 20:24 SP: 4.0 PV: 4.0 DV: 0.0
 19:24 SP: 4.0 PV: 4.0 DV: 0.0
 18:24 SP: 4.0 PV: 3.8 DV: -0.2
 17:24 SP: 4.0 PV: 4.0 DV: 0.0
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 3.8 DV: -0.2
 13:24 SP: 4.0 PV: 4.0 DV: 0.0
 12:24 SP: 4.0 PV: 3.9 DV: -0.1
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.8 DV: -0.2
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 4.1 DV: 0.1
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.7 DV: -0.3
 04:24 SP: 4.0 PV: 4.0 DV: 0.0
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.7 DV: -0.3
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 3.7 DV: -0.3

2025-09-22

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 4.1 DV: 0.1
 21:24 SP: 4.0 PV: 3.9 DV: -0.1
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 4.1 DV: 0.1
 17:24 SP: 4.0 PV: 3.8 DV: -0.2
 16:24 SP: 4.0 PV: 3.8 DV: -0.2
 15:24 SP: 4.0 PV: 3.9 DV: -0.1
 14:24 SP: 4.0 PV: 3.9 DV: -0.1
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 3.8 DV: -0.2
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 4.1 DV: 0.1
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 3.9 DV: -0.1
 06:24 SP: 4.0 PV: 4.0 DV: 0.0
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 3.9 DV: -0.1
 03:24 SP: 4.0 PV: 3.7 DV: -0.3
 02:24 SP: 4.0 PV: 4.1 DV: 0.1
 01:24 SP: 4.0 PV: 3.8 DV: -0.2
 00:24 SP: 4.0 PV: 3.9 DV: -0.1

2025-09-21

23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 3.7 DV: -0.3
 21:24 SP: 4.0 PV: 3.7 DV: -0.3
 20:24 SP: 4.0 PV: 3.7 DV: -0.3
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 3.6 DV: -0.4
 16:24 SP: 4.0 PV: 3.6 DV: -0.4
 15:24 SP: 4.0 PV: 3.6 DV: -0.4
 14:24 SP: 4.0 PV: 3.6 DV: -0.4
 13:24 SP: 4.0 PV: 3.6 DV: -0.4
 12:24 SP: 4.0 PV: 3.6 DV: -0.4
 11:24 SP: 4.0 PV: 3.6 DV: -0.4
 10:24 SP: 4.0 PV: 3.6 DV: -0.4
 09:24 SP: 4.0 PV: 3.7 DV: -0.3
 08:24 SP: 4.0 PV: 3.6 DV: -0.4
 07:24 SP: 4.0 PV: 3.6 DV: -0.4
 06:24 SP: 4.0 PV: 3.6 DV: -0.4
 05:24 SP: 4.0 PV: 3.6 DV: -0.4
 04:24 SP: 4.0 PV: 3.6 DV: -0.4
 03:24 SP: 4.0 PV: 3.6 DV: -0.4
 02:24 SP: 4.0 PV: 3.6 DV: -0.4
 01:24 SP: 4.0 PV: 3.6 DV: -0.4
 00:24 SP: 4.0 PV: 3.6 DV: -0.4

2025-09-24

23:24 SP: 4.0 PV: 3.6 DV: -0.4
 22:24 SP: 4.0 PV: 3.6 DV: -0.4
 21:24 SP: 4.0 PV: 3.6 DV: -0.4
 20:24 SP: 4.0 PV: 3.6 DV: -0.4
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 3.6 DV: -0.4
 16:24 SP: 4.0 PV: 3.6 DV: -0.4
 15:24 SP: 4.0 PV: 3.6 DV: -0.4
 14:24 SP: 4.0 PV: 3.8 DV: -0.2

3

13:24 SP: 4.0 PV: 3.7 DV: -0.1
 12:24 SP: 4.0 PV: 4.0 DV: 0.0
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 4.0 DV: 0.0
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.8 DV: -0.2
 06:24 SP: 4.0 PV: 4.0 DV: 0.0
 05:24 SP: 4.0 PV: 3.9 DV: -0.1
 04:24 SP: 4.0 PV: 3.7 DV: -0.3
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.9 DV: -0.1
 00:24 SP: 4.0 PV: 3.9 DV: -0.1

2025-09-23

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.9 DV: -0.1
 22:24 SP: 4.0 PV: 3.8 DV: -0.2
 21:24 SP: 4.0 PV: 4.1 DV: 0.1
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 3.7 DV: -0.3
 17:24 SP: 4.0 PV: 4.1 DV: 0.1
 16:24 SP: 4.0 PV: 3.8 DV: -0.2
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 3.7 DV: -0.3
 13:24 SP: 4.0 PV: 3.8 DV: -0.2
 12:24 SP: 4.0 PV: 3.9 DV: -0.1
 11:24 SP: 4.0 PV: 3.8 DV: -0.2
 10:24 SP: 4.0 PV: 4.0 DV: 0.0
 09:24 SP: 4.0 PV: 3.8 DV: -0.2
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.7 DV: -0.3
 06:24 SP: 4.0 PV: 3.7 DV: -0.3
 05:24 SP: 4.0 PV: 3.6 DV: -0.4
 04:24 SP: 4.0 PV: 4.2 DV: 0.2
 03:24 SP: 4.0 PV: 3.8 DV: -0.2
 02:24 SP: 4.0 PV: 3.7 DV: -0.3
 01:24 SP: 4.0 PV: 4.1 DV: 0.1
 00:24 SP: 4.0 PV: 3.9 DV: -0.1

2025-09-26

23:24 SP: 4.0 PV: 3.7 DV: -0.3
 22:24 SP: 4.0 PV: 4.1 DV: 0.1
 21:24 SP: 4.0 PV: 3.9 DV: -0.1
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 4.0 DV: 0.0
 18:24 SP: 4.0 PV: 3.9 DV: -0.1
 17:24 SP: 4.0 PV: 3.9 DV: -0.1
 16:24 SP: 4.0 PV: 3.7 DV: -0.3
 15:24 SP: 4.0 PV: 3.6 DV: -0.4
 14:24 SP: 4.0 PV: 3.6 DV: -0.4
 13:24 SP: 4.0 PV: 3.7 DV: -0.3
 12:24 SP: 4.0 PV: 3.6 DV: -0.4
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.7 DV: -0.3
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 3.8 DV: -0.2
 06:24 SP: 4.0 PV: 3.8 DV: -0.2
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 3.9 DV: -0.1
 03:24 SP: 4.0 PV: 3.9 DV: -0.1
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.7 DV: -0.3
 00:24 SP: 4.0 PV: 3.7 DV: -0.3

2025-09-25

23:24 SP: 4.0 PV: 3.9 DV: -0.1
 22:24 SP: 4.0 PV: 3.8 DV: -0.2
 21:24 SP: 4.0 PV: 4.2 DV: 0.2
 20:24 SP: 4.0 PV: 3.9 DV: -0.1
 19:24 SP: 4.0 PV: 3.9 DV: -0.1
 18:24 SP: 4.0 PV: 3.8 DV: -0.2
 17:24 SP: 4.0 PV: 3.9 DV: -0.1
 16:24 SP: 4.0 PV: 3.8 DV: -0.2
 15:24 SP: 4.0 PV: 4.0 DV: 0.0
 14:24 SP: 4.0 PV: 3.8 DV: -0.2
 13:24 SP: 4.0 PV: 4.0 DV: 0.0
 12:24 SP: 4.0 PV: 3.9 DV: -0.1
 11:24 SP: 4.0 PV: 3.7 DV: -0.3
 10:24 SP: 4.0 PV: 3.6 DV: -0.4
 09:24 SP: 4.0 PV: 4.2 DV: 0.2
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 4.0 DV: 0.0
 06:24 SP: 4.0 PV: 3.8 DV: -0.2
 05:24 SP: 4.0 PV: 3.6 DV: -0.4
 04:24 SP: 4.0 PV: 3.6 DV: -0.4
 03:24 SP: 4.0 PV: 4.2 DV: 0.2
 02:24 SP: 4.0 PV: 3.8 DV: -0.2
 01:24 SP: 4.0 PV: 4.1 DV: 0.1
 00:24 SP: 4.0 PV: 3.8 DV: -0.2

2025-09-28

23:24 SP: 4.0 PV: 4.2 DV: 0.2
 22:24 SP: 4.0 PV: 3.8 DV: -0.2
 21:24 SP: 4.0 PV: 4.3 DV: 0.3
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.7 DV: -0.3
 18:24 SP: 4.0 PV: 4.1 DV: 0.1
 17:24 SP: 4.0 PV: 3.9 DV: -0.1
 16:24 SP: 4.0 PV: 3.8 DV: -0.2
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 4.1 DV: 0.1
 13:24 SP: 4.0 PV: 3.8 DV: -0.2
 12:24 SP: 4.0 PV: 3.7 DV: -0.3
 11:24 SP: 4.0 PV: 4.3 DV: 0.3
 10:24 SP: 4.0 PV: 3.8 DV: -0.2
 09:24 SP: 4.0 PV: 4.2 DV: 0.2
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 4.1 DV: 0.1
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 3.6 DV: -0.4
 03:24 SP: 4.0 PV: 4.3 DV: 0.3
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 4.1 DV: 0.1
 00:24 SP: 4.0 PV: 3.9 DV: -0.1

2025-09-27

SP Setting Point
 PV Present Value
 DV Difference Value

부록8. 서식II-01-08, 온도기록지(IP 보관)-자동온도 기록 레코더형

2025.9

23:24 SP: 4.0 PV: 3.9 DV: -0.1
 22:24 SP: 4.0 PV: 3.9 DV: -0.1
 21:24 SP: 4.0 PV: 3.7 DV: -0.3

3

20:24 SP: 4.0 PV: 4.3 DV: 0.
 19:24 SP: 4.0 PV: 3.8 DV: -0.2
 18:24 SP: 4.0 PV: 3.8 DV: -0.2
 17:24 SP: 4.0 PV: 4.0 DV: 0.0
 16:24 SP: 4.0 PV: 3.9 DV: -0.1
 15:24 SP: 4.0 PV: 3.8 DV: -0.2
 14:24 SP: 4.0 PV: 4.0 DV: 0.0
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 4.0 DV: 0.0
 11:24 SP: 4.0 PV: 3.8 DV: -0.2
 10:24 SP: 4.0 PV: 4.1 DV: 0.1
 09:24 SP: 4.0 PV: 3.9 DV: -0.1
 08:24 SP: 4.0 PV: 3.8 DV: -0.2
 07:24 SP: 4.0 PV: 4.0 DV: 0.0
 06:24 SP: 4.0 PV: 3.9 DV: -0.1
 05:24 SP: 4.0 PV: 3.9 DV: -0.1
 04:24 SP: 4.0 PV: 3.8 DV: -0.2
 03:24 SP: 4.0 PV: 3.6 DV: -0.4
 02:24 SP: 4.0 PV: 4.2 DV: 0.2
 01:24 SP: 4.0 PV: 3.9 DV: -0.1
 00:24 SP: 4.0 PV: 3.8 DV: -0.2

2025-09-30

23:24 SP: 4.0 PV: 4.2 DV: 0.2
 22:24 SP: 4.0 PV: 3.8 DV: -0.2
 21:24 SP: 4.0 PV: 3.9 DV: -0.1
 20:24 SP: 4.0 PV: 3.8 DV: -0.2
 19:24 SP: 4.0 PV: 3.6 DV: -0.4
 18:24 SP: 4.0 PV: 3.6 DV: -0.4
 17:24 SP: 4.0 PV: 4.2 DV: 0.2
 16:24 SP: 4.0 PV: 3.7 DV: -0.3
 15:24 SP: 4.0 PV: 3.7 DV: -0.3
 14:24 SP: 4.0 PV: 4.2 DV: 0.2
 13:24 SP: 4.0 PV: 3.9 DV: -0.1
 12:24 SP: 4.0 PV: 4.0 DV: 0.0
 11:24 SP: 4.0 PV: 3.9 DV: -0.1
 10:24 SP: 4.0 PV: 3.6 DV: -0.4
 09:24 SP: 4.0 PV: 4.1 DV: 0.1
 08:24 SP: 4.0 PV: 3.9 DV: -0.1
 07:24 SP: 4.0 PV: 3.9 DV: -0.1
 06:24 SP: 4.0 PV: 4.1 DV: 0.1
 05:24 SP: 4.0 PV: 3.8 DV: -0.2
 04:24 SP: 4.0 PV: 3.6 DV: -0.4
 03:24 SP: 4.0 PV: 4.2 DV: 0.2
 02:24 SP: 4.0 PV: 3.9 DV: -0.1
 01:24 SP: 4.0 PV: 3.8 DV: -0.2
 00:24 SP: 4.0 PV: 4.2 DV: 0.2

2025-09-29

SP Setting Point
 PV Present Value
 DV Difference Value

8 of 8

date of copying

sign